Circuit Breaker for Equipment thermal-magnetic, Flange type, Manual ON/OFF, Screw terminals



#### See below:

## **Approvals and Compliances**

## **Description**

- Flange type
- TMF12-211 Thermal-magnetic circuit breaker
- 1-pole
- Manual ON/OFF type
- Insensitive to shock or vibration
- Bolts and nuts

### **Unique Selling Proposition**

- Tripping characteristic Fast or Slow
- Positively trip-free release
- Available with cover
- Different mounting possibilities

# **Applications**

- Power supplies
- Uninterruptible power supply
- Power tools
- Household appliances

#### References

#### Weblinks

pdf data sheet, html datasheet, General Product Information, Distributor-Stock-Check, Detailed request for product, Product News

## **Technical Data**

Rated Voltage AC	AC 240 V: 50/60 Hz
Rated Voltage DC	28 V
Rated current range AC	0.05 - 15 A, see approbations
Conditional short circuit capacity Inc	IEC 60934: PC1, AC 240 V: 1 kA
Short circuit capacity Icn	IEC 60934: AC 240 V : 200 A
	AC/DC 28 V : 400 A
Degree of Protection	front side IP40 acc. to IEC 60529
Dielectric Strength	50Hz: > 1.5kV
	Impulse 1.2/50 µs: > 2.5 kV
Insulation Resistance	$500\text{VDC} > 100\text{M}\Omega$
Endurance typical	2 x Ir: 5000 switching cycles
Endurance minimum	Manual ON/OFF type AC: 2 x lr, cos φ 0.6:
	DC: 2 x Ir , L/R = 2 - 3 ms: 5000 switching cycles

Overload	IEC: min. 40 trips
	@ 6 x lr, cos φ 0.6
	UL / CSA: min. 50 trips
	@ 1.5 x lr, cos φ 0.75
Allowable Operation Temp.	-5°C to 60°C
Vibration Resistance	± 1.5 mm @ 10 - 60 Hz
	acc. to IEC 60068-2-6, test Fc
	10 G @ 60 - 500 Hz
	acc. to IEC 60068-2-6, test Fc
Shock Resistance	100 G / 6ms
	acc. to IEC 60068-2-27, test Ea
Tripping Type	Thermal-Magnetic
Actuation Type	Manual ON/OFF
Weight	ca. 10g
·	

### **Approvals and Compliances**

Detailed information on product approvals, code requirements, usage instructions and detailed test conditions can be looked up in Details about Approvals

SCHURTER products are designed for use in industrial environments. They have approvals from independent testing bodies according to national and international standards. Products with specific characteristics and requirements such as required in the automotive sector according to IATF 16949, medical technology according to ISO 13485 or in the aerospace industry can be offered exclusively with customer-specific, individual agreements by SCHURTER.

## **Approvals**

The approval mark is used by the testing authorities to certify compliance with the safety requirements placed on electronic products. Approval Reference Type: TM12

Approval Logo	Certificates	Certification Body	Description
_DVE	VDE Approvals	VDE	VDE Certificate Number: 99673
c <b>FL</b> °us	UL Approvals	UL	UR File Number: E71572
<b>®</b>	CSA Approvals	CSA	CSA Certification Record: LR 37712
<b>(W)</b>	CCC Approvals	ccc	CCC Certificate Number: 2020970307003504

## **Product standards**

Product standards that are referenced

Organization	Design	Standard	Description
<u>IEC</u>	Designed according to	IEC 60934	Circuit-breakers for equipment (CBE)
(UL)	Designed according to	UL 1077	Standard for Supplementary Protectors for Use in Electrical Equipment
<b>(W)</b>	Designed according to	GB 17701	Circuit-breaker for equipment

## **Application standards**

Application standards where the product can be used

Organization	Design	Standard	Description
<u>IEC</u>	Suitable for applications acc.	IEC/UL 62368-1	Audio/video, information and communication technology equipment - Part 1: Safety requirements


#### Compliances


The product complies with following Guide Lines


Identification	Details	Initiator	Description
C€	CE declaration of conformity	SCHURTER AG	The CE marking declares that the product complies with the applicable requirements laid down in the harmonisation of Community legislation on its affixing in accordance with EU Regulation 765/2008.
UK CA	UKCA declaration of conformity	SCHURTER AG	The UKCA marking declares that the product complies with the applicable requirements laid down in the British Amendment of Regulation (EC) 765/2008.
RoHS	RoHS	SCHURTER AG	Directive RoHS 2011/65/EU, Amendment (EU) 2015/863
<b>50</b>	China RoHS	SCHURTER AG	The law SJ / T 11363-2006 (China RoHS) has been in force since 1 March 2007. It is similar to the EU directive RoHS.
REACH	REACH	SCHURTER AG	On 1 June 2007, Regulation (EC) No 1907/2006 on the Registration, Evaluation, Authorization and Restriction of Chemicals 1 (abbreviated as "REACH") entered into force.


# Dimension [mm]


TMx12-112















Installation from rear


Installation from front

# Diagrams

TM12-...









TM12-...S

TM12-...SN





Approval		Main circuit			Auxiliary circuit		
		Rated current	Rated Voltage AC	Rated Voltage DC	Rated current	Rated Voltage AC	Rated Voltage DC
	UL 1077 CSA C22.2 No. 235	0.0515 A	240 V	28 V	2 A 3 A	120 V -	- 28 V
	CSA C22.2 No. 235	0.0516 A	240 V	28 V	1 A	240 V	-
	EN 60934	0.0516 A	240 V	28 V	1 A	240 V	28 V
	GB 17701	0.0516 A	240 V	28 V	1 A	240 V	28 V

# Typical internal resistance TMF12

Rated Current [A]	Internal Resistance [ $\Omega$ ]
0.05	335.00
0.50	4.37
1.00	1.23
2.00	0.369
3.00	0.181
4.00	0.097
5.00	0.055
6.00	0.044
7.00	0.0231
8.00	0.0227
9.00	0.0142
10.00	0.0123
11.00	0.012
12.00	0.012
13.00	0.0108
14.00	0.0091
15.00	0.0089
16.00	0.0071

# Typical internal resistance TMT12

Rated Current [A]	Internal Resistance [Ω]
0.05	260.00
0.50	4.03
1.00	1.006
2.00	0.323
3.00	0.161
4.00	0.086
5.00	0.0494
6.00	0.0396
7.00	0.0257
8.00	0.0249
9.00	0.0129
10.00	0.0112
11.00	0.0111
12.00	0.0111
13.00	0.0109
14.00	0.0092
15.00	0.0090
16.00	0.0075


## Effect of ambient temperature

The units are calibrated for an ambient temperature of +23°C. To determine the rated current for a lower or higher ambient temperature, use a correction factor (typical value) from the table below:

Ambient Temperature [°C]	Correction factor
-5	0.87
0	0.90
10	0.95
23	1.00
30	1.05
40	1.12
50	1.20
60	1.30

Example: Rated current = 5 A, Environmental temperature = 50 °C, --> Correction factor = 1.2, Resulting current = 6.0 A

#### **Time-Current-Curves**



## Config. Code

## TM F 12 - 1 2 3 A B C - 1.23

The characters are placeholders for the correspondingly keys of selections from the key tables.

TM <b>F</b> 12 - 1 2 3 A B C - 1.23 <b>= Magnetic release range</b>		Shunt terminal
Magnetic release range	Configuration key	Shunt terminal
Fast	F	TM F 12 - 1
Slow	Т	Setting indication
TM F 12 - <b>1</b> 2 3 A B C - 1.23 = <b>Mounting</b> Mounting	Configuration	Setting indicatio
Screwflange mounting	key	Rated current
TM F 12 - 1 <b>2</b> 3 A B C - 1.23 = Actuation Type		
Actuation Type	Configuration	0.05 A 0.1 A
· · · · · · · · · · · · · · · · · · ·	key	0.1 A
Manual ON/OFF (push/push)	2	0.10 A
TM F 12 - 1 2 <b>3</b> A B C - 1.23 <b>= Terminal</b>		0.3 A
Terminal	Configuration	0.4 A 0.5 A
	key	0.5 A 0.6 A
Screw clamp terminals	2	0.6 A 0.7 A
TM F 12 - 1 2 3 <b>A</b> B C - 1.23 <b>= Auxiliary contact</b>		0.7 A 0.8 A
TWI 12-120 A B O-1.20 - Advinding Contact		0.9 A
Auxiliary contact	Configuration key	1.0
A. William and add		1.1 A
Auxiliary contact	S	1.2 A
TM F 12 - 1 2 3 A <b>B</b> C - 1.23 <b>= Shunt terminal</b>		1.3 A

Shunt terminal	Configuration key
Shunt terminal	N
TM F 12 - 1 2 3 A B <b>C</b> - 1.23 = Setting indication	
Setting indication	Configuration key
Setting indication	R
TM F 12 - 1 2 3 A B C - 1.23 = Rated current	
Rated current	Configuration key
0.05 A	0.05
0.1 A	0.1
0.15 A	0.15
0.2 A	0.2
0.3 A	0.3
0.4 A	0.4
0.5 A	0.5
0.6 A	0.6
0.7 A	0.7
0.8 A	0.8
0.9 A	0.9
1.0	1
1.1 A	1.1
1.2 A	1.2
1.3 A Other rated currents on request	1.3

Rated current	Configuration key	Rated current	Configuration key
1.4 A	1.4	5.0 A	5
1.5 A	1.5	5.5 A	5.5
1.6 A	1.6	6.0	6
1.7 A	1.7	6.5 A	6.5
1.8 A	1.8	7.0 A	7
1.9 A	1.9	7.5 A	7.5
2.0 A	2	8.0 A	8
2.1 A	2.1	8.5 A	8.5
2.3 A	2.3	9.0 A	9
2.5 A	2.5	9.5 A	9.5
2.8 A	2.8	10.0 A	10
3.0 A	3	11.0 A	11
3.3 A	3.3	12.0 A	12
3.5 A	3.5	13.0 A	13
4.0 A	4	14.0 A	14
4.5 A	4.5	15.0 A	15
Other rated currents on request		16.0 A	16
		Other rated currents on request	

#### **Variants**

Rated Current [A]		Construction variants		Config. Code	Order Number
	Auxiliary contact	Shunt terminal	Setting indication		
3			•	TMF12-122R-3	4410.0819
5			•	TMF12-122R-5	4410.0820

Availability for all products can be searched real-time: https://www.schurter.com/en/info-center/supporttools/stock-check-distributors

Packaging Unit	20 Pcs		
----------------	--------	--	--